

F. No. J-11011/990/2007-IA II (I)
Government of India
Ministry of Environment, Forest and Climate Change
(I.A. Division)

Indira Paryavaran Bhawan
Aliganj, Jorbagh Road,
New Delhi -110003

E-mail: lk.bokolia@nic.in
Telefax: 011-24695313
Dated 30th November, 2015

To
The Managing Director
M/s Asian Paint Ltd.
Industrial Development Area,
Patancheru, District Medak
Andhra Pradesh.

Subject: **Expansion of Paint Unit [Paint (from 80,000 TPA to 1,00,000 TPA) and Resins (from 20,000 TPA to 30,000 TPA Emulsion)] at Industrial Development Area, Patancheru, District Medak, Andhra Pradesh by M/s Asian Paints Ltd. – reg. Extension of Validity of EC.**

Ref. : (i) Ministry's letter of even no dated 23rd June, 2008.
(ii) Your letters dated 5th March, 2013 and 2nd December, 2014.

Sir,

This is in continuation of this Ministry's letter referred above and your letter under reference, wherein you have requested for extension of validity of aforesaid environmental clearance (EC) letter for another term.

2. The proposal referred above was placed before the Reconstituted Expert Appraisal Committee (Industry) in its 44th meeting held during 20th -21st July, 2015. The Committee recommended the extension of validity of existing environmental clearance till 22.06.2018.

3. The Ministry accepts the recommendation of the REAC (Industry) and extends the validity of the Environmental Clearance letter no. J-11011/990/2007-IA II (I) dated 23rd June, 2008 till 22.06.2018 subject to compliance of specific and general conditions.

4. Industrial effluent generation shall not exceed 41 m³/day. Industrial effluent shall be treated in the effluent treatment plant (ETP) followed by Reverse Osmosis (RO). RO rejects shall be evaporated in the multiple effect evaporator (MEE) followed agitated thin film drier (ATFD). Treated effluent will be recycled/reused in process/cooling tower make up and boiler feed. Sewage (70 m³/day) will be treated in the sewage treatment plant (STP) and treated sewage will be recycled/reused within plant premises.

5. *No effluent shall be discharged outside the premises and 'Zero' discharge shall be maintained.*

6. Automatic /online monitoring system (24 x 7 monitoring devices) for flow measurement and relevant pollutants in the treatment system to be installed. The data to be made available to the respective SPCB and in the Company's website.

7. Process effluent/any wastewater shall not be allowed to mix with storm water. Storm water drain shall be passed through guard pond.

ll

8. All other conditions stipulated in the environmental clearance letter no. J-11011/990/2007-IA II (I) dated 23rd June, 2008 shall remain the same.

9. This issues with the approval of Competent Authority.



(Lalit Bokolia)
Additional Director

Copy to:-

1. The Principal Secretary, Department of Environment, Forest, Science & Technology, Government of Telangana, Hyderabad, A.P.
2. The Chief Conservator of Forests, Regional Office (Southern Zone, Bangalore) Kendriya Sadan, 4th Floor, E&F Wing, II Block Koramangala, Bangalore-560034.
3. The Chairman, Central Pollution Control Board Parivesh Bhavan, CBD-cum-Office Complex, East Arjun Nagar, New Delhi - 110 032.
4. The Chairman, Telangana Pollution Control Board, Paryavaran Bhawan, A-III, Industrial Estate, Sanath Nagar, Hyderabad - A.P.
5. Monitoring Cell, Ministry of Environment, Forest and Climate Change, Indira Paryavaran Bhavan, Jorbagh Road, New Delhi.
6. Guard File/Monitoring File/Record File.



(Lalit Bokolia)
Additional Director